



URRQ.S3753

## Smoke-automatic Fire Detector Accessories

[See General Information for Smoke-automatic Fire Detector Accessories](#)

**HOME SAFEGUARD INDUSTRIES L L C**

S3753

107 GARLISCH DR

ELK GROVE, IL 60007 USA

**Aerosol tester spray**, Models 1H, 25S, 25-NF, SAT-1 for smoke entry and alarm actuation per NFPA72, paragraph 10.4.2.2-13G. When recommended by the smoke detector manufacturer for specific model detectors. Not for a sensitivity check.

**Aerosol tester spray dispenser**, Model 1490 for use with model 25S Aerosol tester spray, for smoke entry and alarm actuation per NFPA72, paragraph 10.4.2.2-13G. Not for a sensitivity check.

[Last Updated](#) on 2005-02-22

This page and all contents are Copyright © 2005 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2005 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.





## URRQ.GuideInfo Smoke-automatic Fire Detector Accessories

[View Listings](#)[Page Bottom](#)[Print-friendly version](#)[Questions?](#)[Previous Page](#)

### **[Signal and Fire Alarm Equipment and Services] (Detectors, Automatic Fire) (Smoke-automatic Fire Detectors) Smoke-automatic Fire Detector Accessories**

#### **[See General Information for Smoke-Automatic Fire Detectors](#)**

A smoke detector accessory is a device employed to supplement smoke detector operation when connected as part of a fire alarm system. The interconnection is indicated on the installation wiring diagram associated with the detector.

Authorities having jurisdiction should be consulted before installation.

Where model numbers are indicated in the Listings, 100 percent of the manufacturer's production for those models are required to be labeled. Where model numbers are not indicated, the manufacturer is not obliged to label 100 percent of production.

The basic standard used to investigate products in this category is UL 268, "Smoke Detectors for Fire Protection Signaling Systems".

The Listing Mark of Underwriters Laboratories Inc. on the product is the only method provided by UL to identify products manufactured under its Listing and Follow-Up Service. The Listing Mark for these products includes the UL symbol of Underwriters Laboratories Inc. (as illustrated in the Introduction of this Directory) together with the word "LISTED", a control number, and the following product name: "Smoke-Automatic Fire Detector Accessory" .

**[Last Updated](#)** on 1999-07-14

[Page Top](#)[Notice of Disclaimer](#)[Questions?](#)[Previous Page](#)[UL Listed and  
Classified Products](#)[UL Recognized  
Components](#)[Products Certified for  
Canada](#)

This page and all contents are Copyright © 2005 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2005 Underwriters Laboratories Inc.®"